



MUNICIPAL CORPORATION CHANDIGARH

(Public Health Laboratory at Water Works Sector - 39)

TEST - REPORT

Not for legal use

Lab No.: MCPHL/26/ 1096

Date : 27.04.2026

Ref. No. : GMHS/47A/2026/512	Sample Details	Date & Time
Dated : 22.04.2026		
Issued to : The Headmistress Govt. Model High School, Sector - 47,A, Chandigarh.	Collected By	Laboratory Staff
Location : From School tap of Govt. Model High School, Sector - 47,A, Chandigarh.	Collection Date	24.04.2026 08:20 a.m.
Packing : Polypropylene and glass bottle	Received at Lab	09:10 a.m.

Test Result (As Per BIS 10500:2012)

S.No	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	—	7.62
2	Odour	Agreeable	—	Agreeable
3	Taste	Agreeable	—	Agreeable
4	Turbidity	<1	N.T.U.	0.8
5	Total Dissolved Solids	<500	mg/l	182
6	Residual Chlorine	0.2 - 0.4	mg/l	0.2
7	Total Alkalinity (as CaCO ₃)	<200	mg/l	144
8	Total Hardness (as CaCO ₃)	<200	mg/l	128
9	Chlorides (as Cl)	<250	mg/l	06
10	Free & Saline Ammonia	NIL	mg/l	NIL
11	M.P.N. of Coliform Bacilli / 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No. 04/2026-27/315007, dated 22.04.2026, amount Rs. - 3300/-

Note: - Water sample is found "POTABLE".

Chemist,
M.C.P.H. Laboratory,
Chandigarh.

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Endst. No. MCPH/26/-----

Dated : 27.04.2026

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector -17, Chandigarh for Information please.

Chemist,
M.C.P.H. Laboratory,
Chandigarh.

Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Remarks:-

- The results given above are related to the sample as collected and tested in lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or legal purpose.

----- End of Report -----

WATER IS LIFE, SAVE IT